



FORT ERIE

water pollution control plant

**1
9
6
8**

TD227
F66
W38
1968
MOE

c.1
a aa

ONTARIO WATER RESOURCES COMMISSION


Division of Plant Operations

Copyright Provisions and Restrictions on Copying:

This Ontario Ministry of the Environment work is protected by Crown copyright (unless otherwise indicated), which is held by the Queen's Printer for Ontario. It may be reproduced for non-commercial purposes if credit is given and Crown copyright is acknowledged.

It may not be reproduced, in all or in part, for any commercial purpose except under a licence from the Queen's Printer for Ontario.

For information on reproducing Government of Ontario works, please contact ServiceOntario Publications at copyright@ontario.ca



Water management in Ontario

Ontario
Water Resources
Commission

135 St. Clair Ave. W.
Toronto 7
Ontario


We are pleased to present you with the Operating Summary for the water pollution control facilities operated for you during 1968.

Both the financial and technical information presented should be of assistance to your present and future planning in this important phase of municipal activity.

A new format has been devised to allow greater readability with equally detailed content. We trust that this will meet with your approval.

Our staff wish to express their appreciation for your co-operation throughout the year.


D. S. Caverly,
General Manager.


D. A. McTavish, P. Eng.,
Director,
Division of Plant Operations.

LIBRARY COPY

JUN 20 1968

ONTARIO WATER
RESOURCES COMMISSION

COPY #1

TD
227
F66
W38
1968
MOE

aswy



Environment Ontario
Laboratory Library
125 Resources Rd.
Etobicoke, Ontario M9P 3V6
Canada

ONTARIO WATER RESOURCES COMMISSION

CHAIRMAN

Dr. James A. Vance

VICE-CHAIRMAN

J. H. H. Root, M. P. P.

COMMISSIONERS

H. E. Brown

D. A. Moodie

L. E. Venchiarutti

GENERAL MANAGER

D. S. Caverly

ASSISTANT GENERAL MANAGERS

L. E. Owers

K. H. Sharpe

F. A. Voegel

A. K. Watt

COMMISSION SECRETARY

W. S. MacDonnell

DIVISION OF PLANT OPERATIONS

Director

D. A. McTavish

Assistant Director

C. W. Perry

Regional Supervisor

A. C. Beattie

Operations Engineer

R. S. McKittrick

135 St. Clair Avenue West.
Toronto 7

FORT ERIE
water pollution control plant

operated for

THE TOWN OF FORT ERIE

by the

ONTARIO WATER RESOURCES COMMISSION

1968 ANNUAL OPERATING SUMMARY

FOREWORD

● This operating summary outlines the project's technical capabilities and financial status in 1968. Such information mirrors past and present performance, but a major intention is to anticipate the future -- to solve problems before they occur.

The new format in which this year's data are presented is designed to offer a higher level of readability than in the past, without a corresponding decrease in compactness, accuracy and detail.

Although your Regional Operations Engineer carries the major responsibility for the contents of the report, those involved in its preparation are attached to several Commission sections and divisions. The statistics section of the Division of Plant Operations compiled the information for the graphs and charts. The draughting section of the Division of Sanitary Engineering drew the graphs. The Division of Finance provided all cost data.

Only the close co-operation of these departments allowed the publication of this summary.

CONTENTS

Title Page	i
Foreword	ii
'68 Review	1
Project Costs	2
Operating Costs	3
Process Data	5
Conclusions	Inside back cover

'68 REVIEW

A total of 527.08 million gallons of raw sewage was treated at the Fort Erie plant during 1968, as compared to 607.17 million gallons in 1967. The average daily flow for the year was 1.44 million gallons or 80% of the plant design dry weather flow of 1.8 million gallons per day. The dry weather design flow was exceeded 30% of the time during 1968.

The operating cost for the year was \$33,844.08 as opposed to \$27,797.55 in 1967. The operating cost per million gallons of sewage treated increased to \$64.21 from \$45.78, reflecting a decrease in raw sewage and an increase in operating costs. The organic strength of the raw sewage increased slightly in 1968 but remained well below normally accepted values.

Both the primary and secondary digesters were drained and necessary repairs were made to internal piping during the year. Maintenance at the plant and pumping station was once again of high calibre and all structures and equipment were in excellent condition at the year's end.

PROJECT COSTS

NET CAPITAL COST (Final)		\$807,050.52
DEDUCT - Payments from Municipality	\$ 55,000.00	
- Portion Financed by CMHC-MDLB (Final)	535,794.31	<u>590,794.31</u>
Long Term Debt to OWRC		<u>\$216,256.21</u>
Debt Retirement Balance at Credit (Sinking Fund) December 31, 1968		\$ <u>28,531.44</u>
Net Operating		\$ 33,844.08
Debt Retirement		4,364.00
Reserve		4,784.63
Interest Charged		<u>12,141.36</u>
TOTAL		\$ <u>55,134.06</u>

RESERVE ACCOUNT


Balance at January 1, 1968	\$ 24,756.54
Deposited by Municipality	4,784.63
Interest Earned	1,559.31
	<u>\$ 31,100.48</u>
Less Expenditures	<u>636.78</u>
Balance at December 31, 1968	\$ <u>30,463.70</u>

Monthly Operating Costs

MONTH	TOTAL EXPENDITURE	PAYROLL	CASUAL PAY ROLL	FUEL	POWER	CHEMICAL	GENERAL SUPPLIES	EQUIPMENT	REPAIRS & MAINTENANCE	* SUNDRY	WATER	TRAVEL
JAN	1042.18	916.34	-	-	-	-	12.00	22.93	70.35	20.56	-	-
FEB	2918.77	912.09	-	125.18	329.88	1109.85	61.14	-	67.49	269.25	-	43.89
MAR	3525.81	1455.46	-	127.79	408.97	1198.05	102.25	-	131.27	71.64	-	30.38
APRIL	2315.16	912.09	-	152.58	374.92	-	231.36	381.61	95.64	126.08	-	40.88
MAY	6125.97	912.09	57.48	72.76	349.29	-	138.74	482.61	209.71	3732.80	-	169.49
JUNE	2008.49	1059.92	147.02	34.98	363.05	-	71.92	74.79	225.23	110.07	-	(78.49)
JULY	2220.92	927.62	278.17	51.78	339.66	-	151.52	8.35	223.64	82.20	-	157.98
AUG	2284.78	1376.86	340.79	42.78	372.34	-	31.34	-	53.49	23.92	-	43.26
SEPT	1950.65	923.96	51.72	.58	380.10	-	113.15	71.67	332.46	25.91	-	51.10
OCT	2742.08	943.80	56.18	16.78	360.67	1043.27	94.54	-	158.40	8.32	-	60.12
NOV	2252.61	904.61	43.30	18.98	351.65	-	75.35	56.00	54.86	628.06	-	119.80
DEC	4456.66	2112.94	-	84.96	956.13	-	281.35	93.33	856.64	23.92	-	47.39
TOTAL	33844.08	13357.78	974.66	729.15	4586.66	3351.17	1365.66	1191.29	2479.18	5122.73	-	685.80


*SUNDRY INCLUDES SLUDGE HAULING COSTS WHICH WERE \$746.08

BRACKETS INDICATE CREDIT



1968 OPERATING COSTS

TOTAL ANNUAL COST



Yearly Operating Costs

YEAR	M.G.TREATED	TOTAL COST	COST PER MILLION GALLONS	COST PER LB OF BOD REMOVED
1964	512.92	\$23,886.73	\$46.57	18 cents
1965	535.46	24,836.97	46.38	12 cents
1966	603.50	26,123.29	43.29	19 cents
1967	620.69	27,797.55	44.78	15 cents
1968	527.08	33,844.08	64.21	16 cents

Process Data

FLOWS

The total raw sewage flow received at the plant in 1968 was 527.08 million gallons, representing a decrease of 13.2% compared to the total flow of 607.17 million gallons in 1967.

The maximum total flow for one month of 68 million gallons occurred in November. The highest daily recorded flow of 4.89 million gallons as well as the lowest recorded daily flow of 0.36 million gallons occurred in June.


The dry weather design flow of 1.8 million gallons per day was exceeded 30% of the time, as compared to 41% of the time in 1967.

PLANT FLOWS and CHLORINATION


MONTH	TOTAL FLOW mg	AVERAGE DAILY FLOW mg	MAXIMUM DAILY FLOW mg	MINIMUM DAILY FLOW mg	CHLORINE USED lbs.	DOSAGE mg/l
JAN	35.34	1.14	1.84	.37	498	2.2
FEB	40.07	1.38	4.83	.93	519	1.3
MAR	54.99	1.77	4.55	.96	538	1.0
APR	37.69	1.26	3.87	.64	500	1.3
MAY	36.13	1.17	2.60	.59	1476	4.1
JUN	37.40	1.25	4.90	.36	2902	7.8
JUL	31.11	1.00	1.80	.72	2955	9.5
AUG	34.06	1.10	2.79	.41	2940	8.6
SEPT	43.22	1.44	3.07	.85	2752	6.4
OCT	50.69	1.64	3.68	1.13	2660	5.2
NOV	68.00	2.27	4.42	1.12	1242	1.8
DEC	58.38	1.88	4.53	.93	271	.5
TOTAL	527.08	-	-	-	19253	-
AVERAGE	-	1.44	-	-	1604	3.7


COMMENTS

Chlorine is added to the effluent from May 14 to November 23 and 15-minute residual of 0.5 mg/l maintained. Influent chlorination is practised to eliminate odours in the detritor area of the plant.





F L O W S






BIOCHEMICAL OXYGEN DEMAND





SUSPENDED SOLIDS



PLANT EFFICIENCY

MONTH	BIOCHEMICAL OXYGEN DEMAND				SUSPENDED SOLIDS				GRIT
	INF	EFF	RED ^N	REMOVAL	INF	EFF	RED ^N	REMOVAL	REMOVAL
	CONC ^N mg/l	CONC ^N mg/l	%	10 ³ lb	CONC ^N mg/l	CONC ^N mg/l	%	10 ³ lb	
JAN	48	25	48	8.1	83	61	26	7.8	0
FEB	162	51	68	44.5	235	52	78	73.3	0
MAR	59	41	30	9.9	94	34	64	33.0	4
APR	50	21	58	10.9	110	26	76	31.7	3
MAY	54	46	15	2.9	71	54	24	6.1	1
JUN	120	31	74	33.3	104	80	23	9.0	14
JULY	83	39	53	13.7	191	84	56	33.3	1
AUG	64	39	39	8.5	197	56	72	48.0	41
SEPT	71	22	69	21.3	62	38	39	10.4	28
OCT	55	38	31	8.6	88	31	65	28.9	10
NOV	57	27	53	20.4	71	35	51	24.5	12
DEC	60	31	48	17.0	100	34	66	38.5	5
TOTAL	-	-	-	199.1	-	-	-	344.5	119
AVERAGE	74	34	54	16.5	117	49	58	28.7	10

COMMENTS

The average strength of the raw sewage was well below design values, with 74 mg/l BOD versus 190 mg/l design and 117 mg/l SS versus 135 mg/l design. The average BOD and suspended solids values increased 19% and 38% respectively over the 1967 average values.

The removal efficiencies of 54% BOD and 58% suspended solids reflect improved performance over the 46.4% reduction in BOD and 46.8% in suspended solids in 1967.

The average grit removed during 1968 was 0.22 cubic feet per million gallons of raw sewage which is an increase of 55% over 1967 quantities.

SLUDGE DIGESTION and DISPOSAL

MONTH	RAW SLUDGE			DIGESTED SLUDGE			SUPERNATANT		SLUDGE DISPOSAL	
	VOLUME 10 ³ gal	T. S. %	V. S. %	VOLUME 10 ³ gal	T. S. %	V. S. %	VOLUME 10 ³ gal	T. S. %	LIQUID yd ³	DEWATERED yd ³
JAN	38.7	6.3	73	46.0	14.2	43	29.4	.52	273	0
FEB	34.0	4.9	66	0	.6	61	21.0	.23	0	0
MAR	37.9	5.3	77	0	3.9	55	29.4	-	0	0
APR	36.3	5.7	76	0	10.5	56	33.6	.23	0	0
MAY	37.9	5.8	72	90.0	-	-	0	-	723*	0
JUN	37.5	6.1	73	0	-	-	0	-	0	0
JUL	37.4	7.6	69	0	-	-	12.0	.31	0	0
AUG	37.6	9.1	61	0	-	-	37.6	.31	0	0
SEPT	36.2	9.5	65	0	-	-	36.2	.28	0	0
OCT	37.3	7.7	67	0	-	-	37.3	.32	0	0
NOV	36.0	6.8	67	0	-	-	36.0	.25	0	0
DEC	37.6	8.2	53	0	-	-	37.6	.26	0	0
TOTAL	444.4	-	-	136.0	-	-	310.1	-	996	0
AVERAGE	37.0	6.9	68	11.4	7.3	54	31.0	.30	83	0


* Digesters emptied.

COMMENTS


A total of 444,400 gallons of raw sludge was pumped to the digester in 1968 at an average solids content of 6.9%. This is a reduction of 1.6% as compared to the total sludge pumped in 1967.

Both the primary and secondary digesters were completely emptied during the year, and a total of 903 cubic yards of digested sludge was hauled from the plant. All accumulated grit was removed and the digester gas piping modified.

The problem of scum build-up on the surface of the primary digester remains unsolved. A number of ideas has been tried with no success, and research into this problem will continue in 1969.



DIGESTION



LABORATORY LIBRARY



96936000119484

CONCLUSIONS

There was some reduction in the average daily flow over the past year which would indicate a degree of success in eliminating storm water and infiltration into the municipal collection system. Plant efficiency, for the treatment provided, was satisfactory and the structures and equipment were well maintained and in good condition at the conclusion of the year.

DATE DUE		

TD227/F66/W38/1968/MOE
Ontario Water Resources Co
Fort Erie water
pollution control plant: aswy
operating summary c.1 a aa
1968



Environment Ontario
Laboratory Library
125 Resources Rd.
Etobicoke, Ontario M9P 3V6
Canada



Water management in Ontario